

## **Life Safety Code Handbook adopted.**

The Life Safety Code Handbook, specifically the 2024 Edition published by the National Fire Protection Association, a copy of which is on file in the Office of the City Secretary, is hereby adopted and designated as the Life Safety Code of the City. Said code is adopted to the same extent as though such code was copied at length herein, subject, however, to the omissions, additions, supplements, and amendments contained in this article.

## **Amendments to NFPA Life Safety Code.**

The Life Safety Code Handbook is amended in the following respects:

- (1) Section 24.3.5.1 is amended by deleting the section in its entirety.
- (2) Section 43.6.4.1 is amended by deleting this section in its entirety and replacing with the following:

Section 43.6.4.1. In a building with rehabilitation work areas involving over 50 percent of the aggregate building area an automatic fire sprinkler system shall be installed to the code applicable to new construction for this type of occupancy.

- (3) Section 43.6.4.2 is amended by deleting the section in its entirety.
- (4) Section 43.6.4.4 is amended by replacing "up to and including the highest rehabilitation work area floor" with "highest floor."

