

2024 International Energy Conservation Code
Proposed Amendments

G. The International Energy Conservation Code adopted by reference in Section 101.4.6, 2021 International Building Code, is hereby amended as follows:

1. Section C&R102.4(Referenced codes and standards) is amended by adding the following to said section:

“Any reference to the ICC Electrical Code shall mean the National Electrical Code, as adopted and amended by the City of College Station.”

2. Section C&R109 (Means of Appeals) is amended by deleting the section in its entirety.
3. Section C402.6 (Air leakage- building thermal envelope) is amended by adding an exception:

“Exception: The air leakage – thermal envelope shall be considered acceptable when the items listed in Table R402.5.1.1, applicable to the method of construction, are field verified. Where required by the code official, an approved third party, independent from the installer, shall inspect and approve the thermal envelope and insulation installation.”

4. Section R401.3 (Certificate) is amended by deleting the existing text from said section and inserting:

“The certificate shall list the types and efficiencies of heating, cooling and service water heating equipment. Where a gas-fired unvented room heater, electric furnace, or baseboard electric heater is installed in the residence, the certificate shall list “gas-fired unvented room heater,” “electric furnace” or “baseboard electric heater.” as appropriate. An efficiency shall not be listed for gas-fired unvented room heaters, electric furnaces or electric baseboard heaters.”

5. Section R402.5.1.2 (Air LeakageTesting) is amended by adding an exception:

“Exception: Building envelope tightness and insulation installation shall be considered acceptable when the items listed in Table R402.5.1.1, applicable to the method of construction, are field verified. Where required by the code official, an approved third party independent from the installer, shall inspect and approve the air barrier and insulation installation.”

6. *Section R402.5.5 (Air-Sealed Electrical and communication outlet boxes. Is amended by adding the following to the end of the section:

“On-site sealing of boxes is acceptable, when using approved sealant materials”

7. *Section R403.3.3 (Ductwork located outside conditioned space) is amended by adding the following to the end of the section:

“Supply and return air ducts in unconditioned spaces may have an insulation R-Value of 6 when installed in conjunction with an air conditioner having a minimum SEER rating of 16.”

8. Section R403.3.7 (Duct System Testing) is amended by adding an additional exception below said section:

Exception: 5. Duct tightness shall be considered acceptable when the items listed below, applicable to the method of construction, are field verified:

Connections:

- a. Seal core to collar with UL listed mastic or at least 2 wraps of UL 181 listed tape.
- b. Secure connection with mechanical clamp placed over the core and tape.
- c. Pull jacket and insulation back over core. Use a mechanical clamp, two wraps of UL 181 listed tape or UL listed mastic to secure insulation.

Splices

- a. Butt two cores together on a 4" length metal sleeve.
- b. Secure core and sleeve with UL listed mastic or two wraps of UL 181 listed tape
- c. Secure connection with 2 clamps placed over the taped core ends.
- d. Pull jacket and insulation back over core. Use two wraps of UL 181 listed tape or UL listed mastic to secure insulation.

9. Section R403 (Systems) is amended by adding R403.14 to read as follows:

"403.14 Heating equipment. Electrical resistance heat may be used as the primary source of heating for residential use not exceeding five hundred (500) square feet in area."

10. *Section R404.2 (Interior Lighting Controls) Is amended by deleting this section in its entirety.

11. Section R406.6 (Verification by approved agency) is amended by replacing the existing text with:

"The Code Official may require verification of compliance with Section R406 be completed by an approved third party."